

**2025 ANNUAL WATER QUALITY REPORT**  
**TOWN OF PULTENEY WATER DISTRICT #1**  
**PO BOX 165 / 9226 COUNTY ROUTE 74**  
**PULTENEY, NY 14874**  
**PUBLIC WATER SUPPLY ID # NY5030103**

**WHY AM I GETTING THIS REPORT?**

TO COMPLY WITH STATE REGULATIONS, THIS REPORT IS ISSUED TO THE CUSTOMERS OF THE PULTENEY WATER DISTRICT (PWD) TO CONVEY INFORMATION REGARDING THE QUALITY OF THE DRINKING WATER PROVIDED BY THE TOWN OF PULTENEY. THE REPORT ALSO GIVES GENERAL INFORMATION ABOUT THE PULTENEY WATER DISTRICT SYSTEM AND PROVIDES LOCAL CONTACTS FOR CONSUMER QUESTIONS AS WELL AS MEETING DATES SHOULD THE CUSTOMER WISH TO APPEAR BEFORE THE TOWN BOARD CONCERNING ANY WATER QUALITY OR SERVICE ISSUE.

**SYSTEM DESCRIPTION**

THE PULTENEY WATER DISTRICT HAS JUST COMPLETED ITS SEVENTEENTH FULL YEAR OF OPERATION. THE WATER DISTRICT HAS 10 MILES OF LINE AND TWO WATER RESERVOIRS ONE LOCATED ON ROFF HILL ROAD AND THE OTHER ON MILL ST.

THE TOWN PURCHASES ALL OF ITS WATER FROM THE VILLAGE OF PENN YAN. ENCLOSED IS THE VILLAGES CONSUMER CONFIDENCE REPORT FOR THE PREVIOUS YEAR WHICH PROVIDES EXTENSIVE DATA ON THE QUALITY OF THE WATER WE OBTAIN FROM THE PENN YAN WATER FILTRATION FACILITY. YOU ARE ENCOURAGED TO READ THE PENN YAN REPORT. ANY SPECIFIC QUESTIONS REGARDING THE DATA IN THE PENN YAN REPORT SHOULD BE ADDRESSED TO THE VILLAGE OFFICIALS LISTED THEREIN.

**FACTS AND FIGURES**

CURRENTLY WE HAVE 446 WATER CONNECTIONS. THE CURRENT MINIMUM USAGE FEE FOR THOSE CONNECTED TO OUR WATER SYSTEM IS \$160.00/QUARTER FOR UP TO 10,000 GALLONS. THE RATE FOR USAGE OVER THE MINIMUM IS SET AT \$16.00/1000 GALLONS. THE CURRENT WATER CAPITAL CHARGE FOR THE PULTENEY WATER DISTRICT IS \$372.71

**VIOLATIONS**

Our water system had no violations in 2025.

**INFORMATION ON LEAD SERVICE LINE INVENTORY**

THE LEAD AND COPPER RULE REVISIONS (LCRR) REQUIRES EVERY FEDERALLY DEFINED COMMUNITY AND NON- TRANSIENT, NON-COMMUNITY WATER SYSTEM TO DEVELOP A SERVICE LINE INVENTORY (LSLI).

A LEAD SERVICE LINE (LSL) IS DEFINED AS ANY PORTION OF PIPE THAT IS MADE OF LEAD WHICH CONNECTS THE WATER MAIN TO THE BUILDING INLET. AN LSL MAY BE OWNED BY THE WATER SYSTEM, OWNED BY THE PROPERTY OWNER, OR BOTH. THE INVENTORY INCLUDES BOTH POTABLE AND NON-POTABLE SLs WITHIN A SYSTEM. IN ACCORDANCE WITH FEDERAL LEAD AND COPPER RULE REVISIONS (LCRR) OUR SYSTEM HAS PREPARED A LEAD SERVICE LINE INVENTORY AND HAVE MADE IT PUBLICLY ACCESSIBLE BY CONTACTING OUR OFFICE FOR A COPY.

**THIS NOTICE IS BEING SENT TO YOU BY: THE PULTENEY WATER DISTRICT.**  
**STATE WATER SYSTEM ID#: NY5030103.**  
**DATE DISTRIBUTED: APRIL 2024.**

**ANY QUESTIONS?**

THE PULTENEY WATER DISTRICT/MUNICIPAL SERVICES OFFICE GENERALLY HAS SOMEONE IN THE OFFICE MONDAY AND WEDNESDAY FROM 8:00AM-10:00AM. PLEASE NOTE THAT THE

OPERATOR IS IN THE FIELD MOST OF THE DAY. IT IS BEST TO CONTACT THE OFFICE FIRST TO MAKE SURE SOMEONE IS IN THE OFFICE. THE OFFICE NUMBER IS 607-868-4222. IF YOU REACH THE OFFICE AFTER HOURS AND NEED TO REPORT AN EMERGENCY, PLEASE LISTEN CAREFULLY TO THE VOICEMAIL AS IT WILL TELL YOU WHERE TO CONTACT OR LEAVE A MESSAGE FOR THE ANSWERING SERVICE. OUR FEES, RATES, AND APPLICATIONS FOR PERMITS CAN BE OBTAINED ON THE TOWN OF PULTENEY WEBSITE [www.pulteneyny.com](http://www.pulteneyny.com)

IF YOU HAVE ANY QUESTIONS OR CONCERNS ABOUT OUR WATER SYSTEMS PLEASE FEEL FREE TO CONTACT:

OPERATIONS MANAGER – CHUCK DLUZAK OR DEPARTMENT OF HEALTH  
 PHONE - 607-868-4222 HORNELL DISTRICT OFFICE  
 E-MAIL -[pulteneywaterdepartment@gmail.com](mailto:pulteneywaterdepartment@gmail.com) PHONE 607-324-8371

QUESTIONS ABOUT THE QUALITY OF THE PENN YAN PRODUCED WATER SHOULD BE DIRECTED TO:

VILLAGE OF PENN YAN PUBLIC WORKS DIRECTOR – MELISSA GERHARDT  
 PHONE – 315-536-3374  
 E-MAIL – [mgerhardt@villageofpennyan.com](mailto:mgerhardt@villageofpennyan.com)

FURTHER GENERAL DRINKING WATER INFORMATION IS AVAILABLE FROM THE EPA’S SAFE DRINKING WATER HOTLINE: PHONE –1- 800-426-4791

**OPPORTUNITY TO PARTICIPATE**

THE PULTENEY WATER DISTRICT IS ADMINISTERED AND OPERATED BY THE TOWN BOARD, TOWN OF PULTENEY. THE TOWN BOARD’S REGULAR MONTHLY MEETING IS ON THE SECOND WEDNESDAY OF EACH MONTH @ 7PM AT THE TOWN HALL, 9226 COUNTY ROUTE 74, PULTENEY. PLEASE FEEL FREE TO ATTEND A TOWN BOARD MEETING IF YOU WISH TO EXPRESS ANY CONCERNS, OR MAKE ANY SUGGESTIONS REGARDING OUR SYSTEM.

Table of Detected Contaminants							
Contaminant	Violation Yes / No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit of Measure - Ment	MCL G	Regulatory Limit (MCL, AL or TT)	<u>Likely Source of Contamination</u>
Lead  (Include 90% and Range of lowest to Highest levels)	N	9/19/23	90% = <.0010  Range: ND	ug/l	0	AL = 15	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper  (Include 90% and Range of lowest to	N	9/19/23	90%= .069  Range: .0042-.069	mg/l	0	AL = 1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.

Highest levels)							
<u>Total Trihalomethanes (TTHMs)</u> (chloroform, bromodichloromethane, dibromochloromethane, and bromoform)	N	Quarterly 2025 1st 2nd 3rd 4th	Quarterly Avg: 37.4 54.9 104 65 Average 65.32	ugl	N/A	80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic mater.
<u>Haloacetic Acids (HAA5s)</u> (mono-, di- and trichloroacetic acid, and mono- and dibromoacetic acid)	N	Quarterly 2025 1st 2nd 3rd 4th	Quarterly Avg: 23.5 20.3 22.8 26 Average 23.15	ug/l	N/A	80	By-product of drinking water Chlorination.
<u>CHLORINE</u>	N	2025	RANGE .25-1.4	MG/L	4	MRDL=4	WATER ADDITIVE TO CONTROL MICROBES



# **Annual Drinking Water Quality Report for 2025**

**Penn Yan Municipal Utilities Board  
111 Elm Street**

**Penn Yan, NY 14527**

**Public Water Supply ID#: NY6101263**

## **INTRODUCTION**

To comply with State regulations, Penn Yan Municipal Water Treatment Plant, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We would like to report that our system did receive two violations however.

The first Violation was for a Water Sampling violation, for an uncompleted water quality test, not a violation of a maximum contaminant level or any other water quality standard. The second violation was for Monitoring and Reporting Violation – Lead and Copper.

Last year, we conducted tests for over 100 contaminants. None of those contaminants were detected at a level higher than the state allows. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Melissa Gerhardt, Director of Public Works, at (315)536-3374. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly Municipal Utilities Board meetings. The meetings are held at 111 Elm Street, Penn Yan, in the 2<sup>nd</sup> floor MUB meeting room. The meeting is held on the Thursday before the third Tuesday of each month at 9:00 AM. For more information, call the Municipal Office at 315-536-3374 weekdays between 7:30 AM and 4:30 PM. For the hearing impaired, the TDD number is 1-800-662-1220.

## **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. To ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our sole water source is surface water from Keuka Lake. During 2024, our system did not experience any restriction of our water source. The water is pumped from the lake to the Water Treatment Plant located at 1515 West Lake Road. John Collins is the Chief Operator at the plant. After filtration, disinfection, fluoridation, and corrosion control treatment, the water is pumped to a two-million-gallon reservoir on the hill above the plant. The water then enters the distribution system by means of gravity.

## **Source Water Assessment Report**

Source Water Assessment Report A report was completed under the New York State Department of Health's Source Water Assessment Program (SWAP). The information contained in the report assists the State in overseeing public water systems and helps local authorities protect the quality of their source water. It is important to note that source water assessment reports estimate the potential for untreated drinking water sources to be impacted by contamination. These reports do not address the safety or quality of treated, finished, potable tap water.

## **Executive Summary – Water Assessment Report**

This assessment found an elevated susceptibility to contamination for this source of drinking water. The number of agricultural lands in the assessment area results in elevated potential for phosphorus, DBP (disinfection by products) precursor and pesticide contamination. While there are some facilities present, permitted discharges do not likely represent an important threat to source water quality based on their density in the assessment area. However, it appears that the total amount of wastewater discharged to surface water in this assessment area is high enough to further raise the potential for contamination, particularly for protozoa. There is also noteworthy contamination susceptibility associated with other discrete contaminant sources and these facility types include CBS (Chemical Bulk Storage) and IHWS (Inactive Hazardous Waste Site).

## **FACTS AND FIGURES**

Our water treatment facility is a regional plant, owned by the Village of Penn Yan, which serves all 5,024 residents (2024 census), of Penn Yan through 2,335 service connections. In addition, approximately 3,000 residents of the Town of Jerusalem are served through connections at Indian Pines, West Lake Road, East Bluff Drive, Branchport, Guyanoga, and Keuka Park with a total of 1,181 service connections. Approximately 1,000 residents in the Town of Milo along East Lake Road are served through 365 service connections. There are approximately 700 residents in the Village of Dresden and along NYS Route 54 that are also served by the Water Treatment Plant through 242 service connections. The Town of Benton also draws water from Penn Yan Water Treatment plant; Benton currently distributes water to 999 of its residents through 363 connections. In the Town of Pulteney, 658 residents are being served through 430 service connections. The total amount of water produced in 2025 was 358,691,600 gallons. The amount of water delivered to all customers in 2025 was 312,054,731 gallons of which 167,833,439 gallons were sold to Village of Penn Yan accounts and 144,221,292 gallons to customers in the other municipalities. A total of 19,283,121 gallons were unavailable for resale, leaving an unaccounted total of 13,389,748 gallons, which was used to flush mains, fight fires, back wash the plant's filters, water main breaks, or was lost through leakage. The daily average amount of water produced per day in 2023 was 945,454 gallons with highest single day of production totaling 1,670,200 gallons.

The Total User Cost (the annual charge to the customer for water service) is billed monthly and is calculated as follows: The Total User Cost equals the Fixed User Cost (defined as the cost of all indebtedness related to the operation of the water system, divided by the total number of EDUs served across the entire village) multiplied by the total number of EDUs assigned to that account, plus the Variable User Cost (defined as the cost of the annual operating and maintenance costs related to the operation of the water system, divided by the anticipated annual water production for the coming year) multiplied by the number of gallons consumed in that month divided by 1,000. In the June 1, 2025 – May 31, 2026 fiscal year, the Fixed User Cost for 5/8" Service Lines = \$5.52, 1" Service Lines = \$11.05, 1.5" Service Lines = \$22.09, 2" Service Lines = \$44.19, 3" Service Lines = \$56.61, 4" Service Lines = \$102.18, and 6" Service Lines = \$128.42. The Variable User Cost per 1,000 gallons of water consumed for In-Village Residents was \$14.72 and \$22.08 for Out of Village Residents. The other villages and townships served by the Village's water treatment facility are charged a flat rate for water based on the cost of production and set their own rates for the water sold to their customers.

## **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the state regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrates, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The following table depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. This is why some of our data – though representative – could be more than one year old. It should be noted that all drinking water, including bottled drinking water, could reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the drinking water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health's Geneva Office (315-789-3030).

## Annual Water Quality Report Tables

### Inorganic Contaminants

Contaminant	Violation Yes / No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
Fluoride	No	8/6/2025	0.6	ppm	N/A	2.2	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer
Barium	No	8/7/2024	0.015	ppm	2	2	Discharge from drilling waste; discharge from metal refineries; erosion of natural deposits
Nitrate	No	5/7/2025	0.12	ppm	--	10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Copper (2)	No	6/7/2023	(range) 0.01– 0.26  (90th Percentile) 0.13	ppm	--	1.3	Erosion of natural deposits; leaching; corrosion of household plumbing system; wood preservatives
Lead (3)	No	6/7/2023	(range) ND – 23  (90th Percentile) 1.5	ppb	--	15	Erosion of natural deposits; corrosion of household plumbing systems
Arsenic	No	8/7/2024	< 0.001	ppm	--	0.01	Natural erosion; agriculture and manufacturing operation discharge; mostly from wood preservative chemicals
Nickel	No	8/7/2024	0.71	ppm	--	0.1	The source is electroplated metal coatings; alkaline batteries; alloys like metal welding rods and solder
Sodium	No	8/6/2025	2.2	ppm	N.A.	See Health Effects	Naturally occurring; road salt; water softeners; animal waste

(2) The level presented represents the 90<sup>th</sup> percentile of the 30 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. The action level for copper was not exceeded at any of the sites tested.

(3) The level presented represents the 90<sup>th</sup> percentile of the 30 samples collected. The action level for lead was not exceeded at any of the sites tested

## Microbiological Contaminants

Contaminant	Violation Yes / No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>Turbidity</b> <i>Filters Highest Monthly Average</i>	No	8/2025	0.14	NTU	--	TT= 95% of samples  <0.3 NTU: This number is not to exceed 1.0 NTU	Soil Runoff
		9/2025	0.12				
<b>Turbidity</b> <i>Filters Single Highest Reading</i>	No	8/31/2025	0.18	NTU	--	TT= 95% of samples  <0.3 NTU: This number is not to exceed 1.0 NTU	Soil Runoff
		9/1/2025	0.20				
<b>Turbidity</b> <i>Distribution System Highest Monthly Avg.</i>	No	8/2025	0.17	NTU	--	TT= 95% of samples  <0.3 NTU: This number is not to exceed 1.0 NTU	Distribution System
		9/2025	0.17				

**Note:** Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. State regulations require that turbidity in the distribution system must always be below 5.0 NTU.

## Microbiological Contaminants

Contaminant	Violation Yes / No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>Total Coliform</b>	No	Six Samples per Month	--	--	--	MCL = 2 or more positive samples in one month	Naturally present in the environment

## Radiological Contaminants

Contaminant	Violation Yes / No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>Gross Alpha activity</b>	No	7/10/2019	Gross Alpha 0.136	pCi/L	--	15 pCi/L	Erosion of Natural Deposits
Radium-226	No	7/10/2019	<i>Radium-266</i> 0.121	pCi/L	--	5 pCi/L	Erosion of Natural Deposits
Radium-228			+ <i>Radium-228</i> 0.333 Total: 0.454				

## Disinfection By-Products Stage 2

Contaminant	Violation Yes / No	Date of Sample	Level Detected (Avg.)	Unit of Measurement	MCLG	Reg. Limit (MCL, TT, or AL)	Likely Source of Contamination
<b>TTHM</b> <i>(Total Trihalomethanes)</i>	No	2/5/2025 5/7/2025 8/6/2025 11/5/2025	Max LRAA 49.83  Range of Results 22.30 – 85.7	ppb	--	80	By-product of drinking water chlorination needed to kill harmful organisms. THMs are formed when source water contains large amounts of organic matter.
<b>HAA5's</b> <i>(Haloacetic Acids)</i>	No	2/5/2025 5/7/2025 8/6/2025 11/5/2025	Max LRAA 16.75  Range of Results 13.60 – 19.70	ppb	--	60	By-product of drinking water disinfection needed to kill harmful organisms

**Note:** This level represents the highest Locational Running Annual Average calculated from data collect

## Definitions:

**Maximum Contaminant Level (MCL)**: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)**: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)**: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL)**: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)**: A required process intended to reduce the level of a contaminant in drinking water.

**Non-Detects (ND)**: Laboratory analysis indicates that the constituent is not present.

**Nephelometric Turbidity Unit (NTU)**: A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Milligrams per liter (mg/l)**: Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/l)**: Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**ppb**: Parts per billion (same as "micrograms per liter" – ug/L).

**ppm**: Parts per million (same as "milligrams per liter" – mg/L).

## WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements, but we are required to provide the following information on lead in drinking water:

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The Penn Yan Municipal Water Treatment Plant is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Penn Yan Municipal Office at (315) 536-3374 weekdays between 7:30 am and 4:30 pm. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

## IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether your drinking water meets health standards. During 2024, we did not complete all testing for Arsenic, Barium, and Nickel, and therefore cannot be sure of the quality of your drinking water during that time.

The second violation was for Monitoring and Reporting Violation – Lead and Copper. 40 CFR 141.85€ requires that water systems deliver annual consumer notification of lead, galvanized requiring replacement, or lead status unknown service lines and deliver lead service line information materials to affected consumers no later than 30 days after completion of the baseline inventory. 40 CFR 14.90(f)(4) requires that water systems certify that it delivered the materials in accordance with 40 CFR 141.85€ by July 1<sup>st</sup> annually. The Village of Penn Yan failed to deliver lead service line information materials to

affected consumers by November 15<sup>th</sup> 2024. Unknown notification deliveries were delayed as the Village was actively learning the customer side of materials based on inspection as a part of a water meter replacement program, the Unknown Notification letter was being revised to provide more concise information to Village customers, and Larson Design Group was still actively processing an abundance of village record data

## **INFORMATION ON LEAD SERVICE LINE INVENTORY**

A Lead Service Line (LSL), is defined as any portion of a pipe that is made of lead which connects the water main to the building inlet. A Lead Service Line may be owned by the water system, by the property owner, or both. The inventory includes both, potable and non-potable Service Lines within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR), our system has prepared a lead service line inventory and have made it publicly accessible by visiting our website at:

[https://www.health.ny.gov/environmental/water/drinking/service\\_line/NY6101263.htm](https://www.health.ny.gov/environmental/water/drinking/service_line/NY6101263.htm)

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## **INFORMATION ON FLUORIDE ADDITION**

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, we monitor fluoride levels daily to make sure fluoride is maintained at a target level of 0.7 mg/l. During 2025 monitoring showed that fluoride levels in your water were within 0.2 mg/l of the target level for 95% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are several reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

## **SYSTEM IMPROVEMENTS**

Thanks to the continued efforts of water plant staff, in conjunction with Village officials, engineers, regulatory agencies, and supporting contractors, we were able to make great strides in improving water plant functions, reliability, and efficiencies this past year. The continual commitment to complete plant maintenance and improvements ensures the water plant's ability to provide a continuous supply of drinking water through process reliability, redundancy, and efficiency.

In 2025, we rehabilitated the 3<sup>rd</sup> and final filter here at the water plant. As before, this consisted of repainting the interior surfaces of the filter, replacing all the internal components, as well as all the media. This filter is back in service and performing well.

## **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.